

Mark J. Buckley, P.E., PLLC

P.O. Box 401
Willsboro, NY 12996

Phone: (518) 963-4467

email: buckleym1956@gmail.com

Cell: (518) 578-4741

August 17, 2021

Mr. Ira Ballen
166 E. 96th Street
New York, NY 10128

Subject: Soil investigation for Parcel #35.2-4-15.001 on Crowningshield Rd., Jay, NY

Dear Mr. Ballen,

On August 14, 2021 I completed two perc tests and on August 17, 2021 I performed a deep hole investigation for the subject property. Following are the results of the review:

Perc Tests: After the holes were saturated the maximum Perc stabilized at 5 mins.

Perc #3 (SP 3): 5 mins.

Perc #4 (SP 4): 5 mins

Deep Hole Test (TP 2):

24.35 acre Parcel:	0-7"	loam topsoil
	7-18"	silt loam
	18-35"	fine sand
	35-48"	coarse sand
	48-53"	silt
	53-72"	coarse sand and gravel

mottling @ 37"

Should you have any questions please contact me at either of the above listed phone numbers.

Sincerely,



Mark J. Buckley, PE