

Water System Field Compliance Inspection Summary Report

Operation: Wilmington WD (ID: 373931)
Facility Name: WILMINGTON WD
Facility Code: 1500300
Facility Address: Whiteface Mtn Highway, Wilmington, NY 12997
NYS Public Water Supply (PWS) ID: NY1500300

To the Attention of:

Roy C Holzer
TOWN OF WILMINGTON
Po Box 180
Wilmington, NY 12997
Email: royholzer@hotmail.com

Sanitary Survey

Date: September 13, 2024 07:20 AM
Inspector: Marlene Martin (marlene.martin@health.ny.gov)
Responsible Person: Ed Orsi

Summary

Number of Critical Violations Found: 0
Number of Other Violations Found: 0
Number of Deficiencies Found: 0

Reinspection is not Required

Each item found in violation is reported below along with the code requirement.

NO CRITICAL VIOLATIONS REPORTED

NO NON-CRITICAL VIOLATIONS REPORTED

NO DEFICIENCIES REPORTED

Water System Information

Source Type: Surface,
Type of Disinfection: Chlorine (Cl),
Disinfection Waiver Issued? No
4-Log Treatment Installed? No
Coliform Surveillance Sample Collected? No
Chlorine Residual Reading(s):
1) Cl Residual: 0.95 Time: 8:15 AM Location: Entry Point

Water System Notes:

Comments: No violations or deficiencies were observed during the inspection. Please work to address fence maintenance issues as discussed during the inspection. Also, please work on clearing a 12" - 18" band around the storage tanks to eliminate vegetation and install a weed barrier and